

LAB SERVICES

Pump Running Hours to over head tanks :

6 to 9:30 AM 3 to 6:00 PM

Pump Running Hours to Residents :

6 to 9:30 AM 3 to 6:00 PM

Weather :Sunny Cloudy Rainy

| | | |
|-------------------------------|-----|-------|
| Turbidity | 0.5 | N.T.U |
| p ^H | 6.5 | |
| Hardness as CaCO ₃ | | |
| Raw Water | 05 | ppm |
| Treated Water | 65 | ppm |

| | | |
|---|----|-----|
| CHLORINALL (HTH) Additi | 10 | Kgs |
| Settler Addition | 03 | Kgs |
| Lime Addition | 12 | Kgs |
| Calcium Chloride Addition | 20 | Kgs |
| Free residual chlorine at Reservoir(FRC) : <u>1</u> ppm | | |

Date: 09-07-09

FREE RESIDUAL CHLORINE CHECK UPS AT THE FOLLOWING POINTS

- | | |
|------------------------------------|---------|
| 1. Pump House | 0.6 ppm |
| 2. Hospital | 0.2 ppm |
| 3. School | 0.2 ppm |
| 4. Post Office | 0.1 ppm |
| 5. Market Street | 0.2 ppm |
| 6. Police Station | 0.2 ppm |
| 7. Gueat House | 0.1 ppm |
| 8. Officer's Engineers Quarters | 0.2 ppm |
| 9. Public Tap | 0.2 ppm |
| 10. Police Quarters | 0.1 ppm |
| 11. Down Quarters | 0.2 ppm |
| 12. | ppm |
| 13. | ppm |

BACTERIOLOGICAL TESTS :

| | | |
|--------------|--------------------------------|---|
| Collected on | | |
| Result | After 24 hours ok/Turned Black | - |
| | After 24 hours ok/Turned Black | - |
| | After 24 hours ok/Turned Black | - |

Remarks: