

LAB SERVICES

SOURCE : FILTER HOUSE -MOTHUGUEDEM APGENCO.

Pump Running Hours : 6Am to 11Am
 Filter Running : 6Am to 9:30Am
 Water Supply Hours to Residents : 3:00 AM
 Water Supply Hours to Power House 6Am to 10:30Am

Date: 24-08-10

Weather :Sunny Cloudy Rainy

	RAW	TREATED	
Turbidity in N.T.U	<u>4.1</u>	<u>0.2</u>	
CHLORINALL (HTH) Addition	<u>12</u>	Kgs	
Settler Addition	<u>5</u>	Kgs	pH
Lime Addition	<u>3</u>	Kgs	<u>6.98</u>
Calcium Chloride Addition	<u>50</u>	Kgs	<u>7.33</u>
Free residual chlorine at Reservoir(FRC) in ppm :	Hardness as CaCO ₃		
	<u>17</u>	ppm	
	<u>65</u>	ppm	
1. 1.0 ppm	2.1.0 ppm	3.1.0 ppm	4. ppm
5. ___PPm	6. ___ ppm	7. ___ ppm	8. ___ppm

FREE RESIDUAL CHLORINE CHECK UPS AT THE FOLLOWING POINTS

- | | | | |
|------------------------|----------------------------------|-----|---|
| 1. I.B | <input type="text" value="0.2"/> | ppm | |
| 2. AE Quarters | <input type="text" value="0.4"/> | ppm | |
| 3. 6D Line | <input type="text" value="0.3"/> | ppm | |
| 4. 6g Line | <input type="text" value="0.2"/> | ppm | Collected at 2C/39 Quarters |
| 5. 2B Quarters | <input type="text" value="0.4"/> | ppm | After 24 hours ok/Turned Black <input type="text" value="-"/> |
| 6. 2F Quarters | <input type="text" value="0.3"/> | ppm | After 24 hours ok/Turned Black <input type="text" value="-"/> |
| 7. 2C Quarters | <input type="text" value="0.2"/> | ppm | After 24 hours ok/Turned Black <input type="text" value="-"/> |
| 8. DAV School | <input type="text" value="0.2"/> | ppm | |
| 9. Project Hostel | <input type="text" value="0.4"/> | ppm | |
| 10. Post Office | <input type="text" value="0.4"/> | ppm | |
| 11. Old Hostel | <input type="text" value="0.5"/> | ppm | |
| 12. 2C/1 Donkaryi Line | <input type="text" value="0.5"/> | ppm | |
| 13. CE Office | <input type="text" value="0.2"/> | ppm | |
| 14. Public Tap | <input type="text" value="0.4"/> | ppm | |
| 15. 1st Ring Road | <input type="text" value="0.5"/> | ppm | |
| 16. 2nd Ring Road | <input type="text" value="0.3"/> | ppm | |
| 17. Ganesh Temple | <input type="text" value="0.2"/> | ppm | |
| 18. Maszid Line | <input type="text" value="0.3"/> | ppm | |
| 19. 327 Union Office | <input type="text" value="0.2"/> | ppm | |
| 20 F-5 Typing Building | <input type="text" value="0.4"/> | ppm | |