

LAB SERVICES

Date: 11-04-09

Pump Running Hours : 5:30 to 10:00 AM 2:00 to 6:00 PM
Filter Running : 6:00 to 10:00 AM 2:00 to 6:00 PM
Water Supply Hours to Residents : 6:00 to 10:00 AM 2:00 to 6:00 PM
Water Supply Hours to Power House : 24 Hours

Weather : Sunny Cloudy Rainy

CHLORINALL (HTH) Addition	<u>20</u>	Kgs	Turbidity	<u>3.1</u>	N.T.U
Settler Addition	<u>35</u>	Kgs	p ^H	<u>7.5</u>	
Lime Addition	<u>10</u>	Kgs	Hardness as CaCo ₃		
Calcium Chloride Addition	<u>60</u>	Kgs	Raw Water	<u>08</u>	ppm
Free residual chlorine at Reservoir(FRC) :	<u>0.5</u>	ppm	Treated Water	<u>66</u>	ppm

FREE RESIDUAL CHLORINE CHECK UPS AT THE FOLLOWING POINTS

1. Filter House ppm
2. Power House ppm
3. Guest House ppm
4. Post Office ppm
5. Hospital ppm
6. Staff Quarters ppm
7. Workers Quarters ppm
8. Market Street ppm
9. Public Tap ppm
10. Police Quarters ppm
11. Katchmguda ppm
12. Bandabasi ppm
13. Makuput ppm
14. T.P.Dam ppm
15. ppm

BACTERIOLOGICAL TESTS :

Collected at Guest House
Hours : 9:30 AM

Result	After 24 hours ok/Turned Black	<input type="text" value="No"/>
	After 24 hours ok/Turned Black	<input type="text" value="No"/>
	After 24 hours ok/Turned Black	<input type="text" value="No"/>

Remarks: **Good Water for Drinking**