

LAB SERVICES

SOURCE :FILTER HOUSE - POLLURU APGENCO

Pump Running Hours : _____
 Filter Running : _____
 Water Supply Hours to Residents : _____
 Water Supply Hours to Power House : _____

Date: 24-08-10

Weather :Sunny Cloudy Rainy Turbidityin N.T.U : RAW WATER 5

TREATED WATER 1.1

CHLORINALL (HTH) Addition 5 Kgs

P^H: RAW WATER 6.94

Settler Addition 10 Kgs

TREATED WATER 7.37

Lime Addition 3 Kgs

6.5

Calcium Chloride Addition 25 Kgs

Raw Water 17 ppm

Free residual chlorine at Reservoir(FRC) :

Treated Water 70 ppm

1. 1.0 PPM 2. 1.0 PPM 3. 1.0 PPM

FREE RESIDUAL CHLORINE CHECK UPS AT THE FOLLOWING POINTS

- | | |
|------------------------------|--------------------------------------|
| 1. 33/KVSS | <input type="text" value="0.2"/> ppm |
| 2. 2C/12 | <input type="text" value="0.2"/> ppm |
| 3. 2G/12 | <input type="text" value="0.5"/> ppm |
| 4. DR/8 | <input type="text" value="0.5"/> ppm |
| 5. 6D/15 | <input type="text" value="0.5"/> ppm |
| 6. 2E/1 | <input type="text" value="0.6"/> ppm |
| 7. 2F/10 | <input type="text" value="0.5"/> ppm |
| 8. Elementary School | <input type="text" value="0.6"/> ppm |
| 9. O&M Stores | <input type="text" value="0.6"/> ppm |
| 10. Public Tap at Pump House | <input type="text" value="0.2"/> ppm |
| 11. 2C/6 | <input type="text" value="0.5"/> ppm |
| 12. 6G/1 | <input type="text" value="0.5"/> ppm |
| 13. Inspection Bangalow | <input type="text" value="0.2"/> ppm |
| 14. H.T Stores | <input type="text" value="0.2"/> ppm |
| 15. Public Tap at DR Type | <input type="text" value="0.5"/> ppm |
| 16. APEE union office (1104) | <input type="text" value="0.5"/> ppm |
| 17. Unoin Office (327) | <input type="text" value="0.6"/> ppm |
| 18. Tempel | <input type="text" value="0.5"/> ppm |
| 19. Church | <input type="text" value="0.5"/> ppm |
| 20. Hostel | <input type="text" value="0.6"/> ppm |

BACTERIOLOGICAL TESTS :

Collected at	O&M Stores
Result :	
After 24 hours ok/Turned Black	<input type="text" value="No"/>
After 24 hours ok/Turned Black	<input type="text" value="No"/>
After 24 hours ok/Turned Black	<input type="text" value="No"/>

Remarks: