

GREATER VISAKHAPATNAM MUNICIPAL CORPORATION

Name of Work: Operation and Maintenance of Residual Chlorine in the entire city distribution and transmission system

Section: 1500 KL RESERVOIR

Source: RAIWADA

FREE RESIDUAL CHLORINE CHECKUPS IN PPm AT THE FOLLOWING POINTS

Date 24-08-10

1500 KL RESERVOIR

Hours	Level in Feet	FRC in PPm	FRC IN PPm at Blocks					
			24	22	18	15	10	TSR
5:00	10.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
6:00	10.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
7:00	5.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
8:00	3.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
9:00	2.0	1.5	1.5	1.5	1.5	1.5	1.5	0.5
10:00	2.0	1.5	1.5	1.5	1.5	1.5	1.5	0.5
11:00	2.0	1.5	1.5	1.5	1.5	1.5	1.5	0.5
12:00	2.5	1.5	1.5	1.5	1.5	1.5	1.5	0.5
13:00	3.5	2.0	1.5	1.5	1.5	1.5	1.5	0.5
14:00	5.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
15:00	5.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
16:00	4.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
17:00	4.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
18:00	4.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
19:00	4.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5
20:00	4.5	2.0	1.5	1.5	1.5	1.5	1.5	0.5
21:00	4.5	2.0	1.5	1.5	1.5	1.5	1.5	0.5
22:00	5.0	1.5	1.5	1.5	1.5	1.5	1.5	0.5
23:00	6.5	1.5	1.5	1.5	1.5	1.5	1.5	0.5
24:00	7.0	1.5	1.5	1.5	1.5	1.5	1.5	0.5
1:00	6.5	1.5	1.5	1.5	1.5	1.5	1.5	0.5
2:00	7.5	1.5	1.5	1.5	1.5	1.5	1.5	0.5
3:00	6.5	2.0	1.5	1.5	1.5	1.5	1.5	0.5
4:00	8.0	2.0	1.5	1.5	1.5	1.5	1.5	0.5

Bacteriological Test

Collected at
Time

Results:

After 24 Hours - Ve
After 48 Hours - Ve

Bacteriological Test

Collected at
Time

Results:

After 24 Hours - Ve
After 48 Hours - Ve

Bacteriological Test

Collected at
Time

Results:

After 24 Hours - Ve
After 48 Hours - Ve

Bacteriological Test

Collected at
Time

Results:

After 24 Hours - Ve
After 48 Hours - Ve