

GREATER VISAKHAPATNAM MUNICIPAL CORPORATION

Name of Work: Operation and Maintenance of Residual Chlorine in the entire city distribution and transmission system

Date: **24-08-10**

Section: **Mindhi**

Source: **RAIWADA**

FREE RESIDUAL CHLORINE CHECKUPS IN PPM AT THE FOLLOWING POINTS

MINDHI

Hours Mindi Reservoir	FRC IN PPM at Blocks								
	Level in Feet	FRC in PPm	13 Mulagada	14 R.T.C.Depot	15 Section Office	16 Durga Nagar	17 R.K.Puram	18 Kakarlova	Akkireddy Palem
5:00	15	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
6:00	12	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
7:00	10	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
8:00	8	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
9:00	5	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
10:00	6	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
11:00	8	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
12:00	10	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
13:00	12	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
14:00	15	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
15:00	15	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
16:00	15	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
17:00	15	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
18:00	15	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
19:00	12	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
20:00	10	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
21:00	8	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
22:00	6	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
23:00	7	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
24:00	8	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
1:00	9	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
2:00	10	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
3:00	12	2.0	1.5	1.5	1.5	1.5	1.5	1.0	
4:00	13	2.0	1.5	1.5	1.5	1.5	1.5	1.0	

Bacteriological Test

Bacteriological Test

Collected at **6 Lack Reservoir**
Date **5:00 AM**

Collected at **Akkireddy Palem**
Date **6:00 AM**

Results:

After 24 Hours - Ve
After 48 Hours - Ve

Results:

After 24 Hours - Ve
After 48 Hours - Ve