

GREATER VISAKHAPATNAM MUNICIPAL CORPORATION

Name of Work: Operation and Maintenance of Residual Chlorine in the entire city distribution and transmission system

Section: YENDADA WATER WORKS

Source: GOSTANI & GHAMBHEERAM

FREE RESIDUAL CHLORINE CHECKUPS IN PPM AT THE FOLLOWING POINTS

Date: 24-08-10

YENDADA

Hours	Level in	FRC in PPM at Blocks						
		FRC in PPM		13	15	16, M.V.P	17	TSR
		12"	20"	Sagar Nagar	Visalaxinagar	Venkojipalem	Seethammadh	
5:00	3.8	1.0	2.0	1.0	1.0	1.5	1.5	0.5
6:00	2.6	1.0	2.0	1.0	1.0	1.5	1.5	0.5
7:00	2.1	1.0	2.0	1.0	1.0	1.5	1.5	0.5
8:00	3.0	1.0	2.0	1.0	1.0	0.0	1.5	0.5
9:00	2.1	1.0	2.0	1.0	1.0	1.5	1.5	0.5
10:00	3.2	1.0	2.0	1.0	1.0	1.5	1.5	0.5
11:00	3.2	1.0	2.0	1.0	1.0	1.5	1.5	0.5
12:00	4.0	1.0	2.0	1.0	1.0	1.5	1.5	0.5
13:00	4.1	1.0	2.0	1.0	1.0	1.5	1.5	0.5
14:00	5.2	1.0	2.0	1.0	1.0	1.5	1.5	0.5
15:00	5.6	1.0	2.0	1.0	1.0	1.5	1.5	0.5
16:00	5.8	1.0	2.0	1.0	1.0	1.5	1.5	0.5
17:00	5.6	1.0	2.0	1.0	1.0	1.5	1.5	0.5
18:00	5.6	1.0	2.0	1.0	1.0	1.5	1.5	0.5
19:00	5.4	1.0	2.0	1.0	1.0	1.5	1.5	0.5
20:00	5.0	1.0	2.0	1.0	1.0	1.5	1.5	0.5
21:00	5.0	1.0	2.0	1.0	1.0	1.5	1.5	0.5
22:00	5.0	1.0	2.0	1.0	1.0	1.5	1.5	0.5
23:00	5.0	1.0	2.0	1.0	1.0	1.5	1.5	0.5
24:00	4.6	1.0	2.0	1.0	1.0	1.5	1.5	0.5
1:00	4.4	1.0	2.0	1.0	1.0	1.5	1.5	0.5
2:00	4.2	1.0	2.0	1.0	1.0	1.5	1.5	0.5
3:00	4.0	1.0	2.0	1.0	1.0	1.5	1.5	0.5
4:00	4.0	1.0	2.0	1.0	1.0	1.5	1.5	0.5

Bacteriological Test

Collected at Sagar Nagar Tank
Time 9:15 AM

Results: After 24 Hours -
After 48 Hours -

Bacteriological Test

Collected at Yendada 20"
Time 7:00 AM

Results: After 24 Hours - - Ve
After 48 Hours - - Ve