

BHEEMUNIPATNAM MUNICIPALITY

Name of : Operation and maintenance of turbidity ,P^H and free Residual Chlorine in Drinking Water System.

Date: 19-08-10

	BHEEMILI	CHITTIVALASA	BHAGEERATHI
TURBIDITY IN NTU :	2.1	1.8	1.8
P ^H :	7.5	7.5	7.5
FRC IN PPM :	2.00	2.00	2.00
HARDNESS AS CaCo ³ :	200	190	190

FREERESIDUAL CHLORINE CHECKUPS AT THE FOLLOWING POINTS

BHEEMILI	CHITTIVALASA	THAGARAPUVALASA
1 THOTA VEEDHI (ST.ANN'S) 1.0 Ppm	1 SANTA PETA/BHEEMILI RD(12 TH) 1.5 Ppm	1 SIVALAYAM(1ST) 1.0 Ppm
2 THOTA VEEDHI (CYCLONE SHELTER) 1.0 Ppm	2 SANTA PETA/CHAKALI PETA(12 TH) 1.0 Ppm	2 RAJU VEEDHI (7TH) 1.5 Ppm
3 RTC BUS STAND 0.5 Ppm	3 SEETHARAMA TEMPLE(5TH) 1.0 Ppm	3 SARASWATHI AIDED SCHOOL (8TH) 1.0 Ppm
4 BANK COLONY 0.5 Ppm	4 NATARAJU THEATRE(5TH) 1.5 Ppm	4 KUMMARAVEEDHI (6TH) 1.0 Ppm
5 BRAHMANA VEEDHI 1.0 Ppm	5 FACTORY SCHOOL (13TH) 1.0 Ppm	5 GOLLAVEEDHI (11TH) 1.5 Ppm
6 BOYA VEEDHI 0.5 Ppm	6 PERIKI VEEDHI (13TH) 1.0 Ppm	6 OLD LOCAL OFFICE ROAD (8TH) 1.0 Ppm
7 BOMMALA WELL 0.5 Ppm	7 RAMAKRISHNA SCHOOL (13TH) 0.5 Ppm	7 JOGAVARI VEEDHI(8TH) 0.5 Ppm
8 YEGUVA PETA 1.0 Ppm	8 VANI VIDYANIKETHAN (13TH) 1.0 Ppm	8 SANTHAPETA/HARIJANPETA(12TH) 1.0 Ppm
9 KONDAMMA HOUSE 1.0 Ppm	9 KOTTA PETA SIVALAYAM(2ND) 1.0 Ppm	9 BALAJINAGAR (8TH) 1.5 Ppm
10 MAIN ROAD KONDALA RAO HOUSE 1.0 Ppm	10 IV LINE 1.0 Ppm	10 I LINE 1.0 Ppm
11 VIAG ROAD 0.5 Ppm	11 V LINE 1.5 Ppm	11 II LINE 1.0 Ppm
12 GADU VEEDHI 0.5 Ppm	12 VI LINE 0.5 Ppm	12 III LINE 0.5 Ppm
	13 VII LINE 0.5 Ppm	

Bacteriological Test

Collected at 3rd line
Time 10:30AM

Results:

After 24 Hours - Ve
After 48 Hours - Ve

Bacteriological Test

Collected at 5 th line
Time 01:00PM

Results:

After 24 Hours - Ve
After 48 Hours - Ve

Bacteriological Test

Collected at 2nd line
Time 1:30pm

Results:

After 24 Hours - Ve
After 48 Hours - Ve

Note: ** N.S = No Supply