

**PARVATHIPURAM MUNICIPALITY**

**Name of Work: Operation and Maintenance of Residual Chlorine in  
the entire city distribution and transmission system**

Section : **KOTHAVASA Reservoir**

**FREE RESIDUAL CHLORINE CHECKUPS IN PPM AT THE FOLLOWING POINTS  
Public Fountains & House Service Connections**

**DATE 08-08-11**

<b>1.Nandamuri Colony</b>		<b>9.Kotta Veedhi</b>		<b>Katiki Veedhi</b>	
11-1-14	1.0	10-1-65	1.0	9-1-30	1.0
FRC in PPM		FRC in PPM		FRC in PPM	
11-1-131	1.0	10-10-12	1.0	9-1-26	1.0
FRC in PPM		FRC in PPM		FRC in PPM	
11-1-6	1.0	<b>10.Sai ram Colony</b>		9-1-21	1.0
FRC in PPM		4-5-19	1.0	FRC in PPM	
<b>2.Naidu Veedhi</b>		FRC in PPM		9-1-15	1.0
11-4-111	1.0	4-5-54	1.0	FRC in PPM	
FRC in PPM		FRC in PPM			
11-4-89	1.0	<b>11.Manikanta Colony</b>			
FRC in PPM		10-2-76	1.0		
11-4-72	1.0	FRC in PPM			
FRC in PPM		10-2-115	1.0		
<b>3.Peda Vedhi</b>		FRC in PPM			
19-27	1.0	<b>12.China magdiga veedi</b>			
FRC in PPM		8-1-40	1.0		
11-3-82	1.0	FRC in PPM			
FRC in PPM		<b>13.Peda Madiga veedhi</b>			
11-3-137	1.0	23-5	1.0		
FRC in PPM		FRC in PPM			
<b>4.Mondi Veedhi</b>		<b>13.Sweepers veedhi</b>			
10-3-75	1.0				
FRC in PPM					
10-3-6	1.0	<b>14.Pallem Vari</b>			
FRC in PPM		5-6-3	1.0		
<b>5.Main Road</b>		FRC in PPM			
19-12	1.0	<b>15.Deepti Lodge</b>			
FRC in PPM		9-1-61	1.0		
26-12	1.0	FRC in PPM			
FRC in PPM		9-1-48	1.0		
25-6	1.0	FRC in PPM			
FRC in PPM					
25-7-12	1.0				
FRC in PPM					
21-3-15	1.0				
FRC in PPM					

**Bacteriological Test**

Collected at : **Nandamuri Colony** **Katika Veedhi**

Time : **7:15am** **4:50pm**

**Result**

After 24 Hours : **-** ve

After 48 Hours : **-** ve

After 72 Hours : **-** ve